

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

1	6	0	5	1	0	0	3	2	8	7	1	1	2	4	3	2	8	1	2	2	2	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 With unit 2 in mode 5 (0% power) at 0630 CST on 11/24/82, one refueling water
0 3 storage tank (RWST) level channel (LT-63-52) was declared inoperable due to
0 4 failure to meet surveillance requirements. This required entry into action
0 5 statement 18 of LCO 3.3.2. There was no effect upon public health and safety.
0 6 Previous occurrences - one (SQRO-50-327/82108).

0 7 | _____

0 8 | _____

7 - 8 9

SYSTEM CODE I B 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE T 15		VALVE SUBCODE Z 16							
EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 1 3 4 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32									
ACTION TAKEN E 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER L 25		COMPONENT MANUFACTURER B 0 8 0	

1 0 During a review of SI-202, "Periodic Calibration of Safety Injection System
1 1 Instrumentation," it was discovered that on 11/09/82 the level channel was found
1 2 out of tolerance during calibration. This was caused by transmitter drift. The
1 3 loop was recalibrated and returned to service at 1630 CST on 11/09/82. No further
1 4 action is planned on the Barton Model 752 transmitter.

FACILITY STATUS		% POWER			OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION					
1	5	G	28	0	0	0	29	NA	B	31	Test review	32

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (75) LOCATION OF RELEASE (36)

1 6 2 33 4 34 NA NA

7 8 9 10 11 44 45 46 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	17	Z	3R	NA	

PERSONNEL INJURIES					
NUMBER			DESCRIPTION		
1	8		0	0	0
			(40)	NA	

8301030252 821222

1	2	3	4	5	6	7	8	9	10	11	12
LOSS OF OR DAMAGE TO FACILITY										PDR ADOCK 05000328	
TYPE DESCRIPTION										S PDR	
1	9	7	42	NA							

ISSUED		DESCRIPTION		PURITY		NRC USE ONLY	
7	6	N	NA	(45)			