

ILLINOIS POWER COMPANY



1606-L
U-10024

CLINTON POWER STATION, P.O. BOX 678, CLINTON, ILLINOIS 61727

January 17, 1983

Docket Number 50-461

Mr. Frank Jablonski
Project Inspector
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: 10 CFR 21 Defects
Affecting Clinton Power Station

Dear Mr. Jablonski,

In response to your telephone conversation with our R.D. Weber on December 1, 1982 (Ref: Record of Coordination, Y-12943, 1606-L, dated December 2, 1982), Illinois Power is placing into effect a system which notifies the NRC (Region III) of those 10 CFR Part 21 defects that affect Clinton Power Station and which were previously reported to the Commission by others (vendors, contractors, etc.). This system will be reflected in our procedures which implement the requirements of 10CFR21, by February 1, 1983.

To summarize this subject, the following 10 CFR Part 21 defects which affect Clinton Power Station have been reported by others to the NRC and are considered "open" at this time:

1. Grounding of flexible conduit in PGCC. Reported to the US NRC, Office of I&E, Washington, DC on 10/29/80 by General Electric Co.
2. Divisional separation in NSPS power distribution panel. Reported to the US NRC, Office of I&E (Region V) on 8/7/80 by General Electric Co.
3. RPV water level transmitters and trip units. Reported to the US NRC, Office of I&E, Washington, DC on 8/19/81 by General Electric Co.
4. Coaxial cable supplied by Rockbestos (Cat. No. RSS-6-104). Reported to the US NRC, Office of I&E, Washington, DC on 5/15/81 by General Atomics.
5. Wipe settings on HFA relays. Reported to the US NRC, Office of I&E, Washington, DC on 7/28/82 by General Electric Co.

8301250167 830117
PDR ADOCK 05000461
S PDR

JAN 20 1983


IE19

Mr. Frank Jablonski

-2-

We trust that this letter satisfies your request for notification on these matters. If you require additional information on the above issues, please do not hesitate to call.

Yours very truly,

A handwritten signature in dark ink, appearing to read "D. P. Hall". The signature is stylized with a large, looped initial "D" and a cursive "P. Hall".

D. P. Hall
Vice President

cc: NRC Resident Inspector
Illinois Department of Nuclear Safety
Manager-Quality Assurance