

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 8 9 14 15 25 26 30 37 CAT 58

REPORT SOURCE 1 6 0 5 0 0 0 3 1 7 1 1 2 9 8 2 8 1 2 1 5 8 2 9
 60 61 66 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

2 On November 29, 1982, following a shift of No. 2B Vital Bus power source in preparation
 3 for planned maintenance on No. 1 Station Power Transformer, the Control Room Operator
 4 observed that the P-250 Computer had shutdown. Since it utilizes the computer data
 5 and memory, the Reactor Coolant System (RCS) subcooling monitor was rendered inoperable,
 6 and Action Statement 3.3.3.7a was entered. Redundant wide range RCS pressure and
 7 temperature indication and steam tables were available, and the event constituted
 8 operation in a degraded mode in accordance with Technical Specification 6.9.1.9.b.
 80

SYSTEM CODE 11 I E 12 CAUSE CODE 13 G 14 COMPONENT CODE 15 F 16 VALVE SUBCODE 17 Z
 9 10 11 12 13 14 15 16 17 18 19 20
 17 LER RO REPORT NUMBER 18 8 19 2 20 EFFECT ON PLANT 21 Z 22 SHUTDOWN METHOD 23 Z 24 HOURS 25 0 0 0 0
 21 22 23 24 25 26 27 28 29 30 31 32
 ACTION TAKEN 33 A 34 Z 35 FUTURE ACTION 36 Z 37 ATTACHMENT SUBMITTED 38 Y 39 NPRO-4 FORM SUB. 40 Y 41 PRIME COMP. SUPPLIER 42 A 43 COMPONENT MANUFACTURER 44 S 45 2 46 5 47 0 48 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

0 Investigation revealed that the computer had shutdown due to failure of the inverter
 1 power supply. The power supply problem resulted from a failed oscillator circuit board.
 2 The board was replaced, the computer was restored to operation and the action state-
 3 ment was terminated.
 4
 80

FACILITY STATUS 5 E 6 % POWER 7 0 8 1 9 OTHER STATUS 10 NA 11 METHOD OF DISCOVERY 12 A 13 DISCOVERY DESCRIPTION 14 Operator Observation 15
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 ACTIVITY CONTENT 6 2 7 2 8 3 9 AMOUNT OF ACTIVITY 10 NA 11 LOCATION OF RELEASE 12 NA 13
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 PERSONNEL EXPOSURES 7 0 8 0 9 TYPE 10 Z 11 DESCRIPTION 12 NA 13
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 PERSONNEL INJURIES 8 0 9 TYPE 10 Z 11 DESCRIPTION 12 NA 13
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 LOSS OF OR DAMAGE TO FACILITY 9 2 10 NA 11 DESCRIPTION 12 NA 13
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
 PUBLICITY 10 2 11 NA 12 DESCRIPTION 13 NA 14
 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

8301250373 830111
 PDR ADOCK 05000311
 S PDR

NRC USE ONLY

NAME OF PREPARER

R. Frahm

PHONE

(609) 935-6000 Ext 3078