



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 14, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-075/03L-0
ER 100450 FILE 841-23
PLA- 1487

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached, please find a copy of Licensee Event Report No. 82-075/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that a diesel generator experienced an erroneous trip caused by a jacket water cooler high temperature switch.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cw

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

IER