



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

January 21, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Barriers Opened to Route
Cables for Modifications to
the Transient Test System
LER 82-176/99 X-0
AECM-83/50

On December 15, and 17, 1982, fire barriers were opened to route cables used for modifications to the transient test system. An hourly fire watch was established in accordance with Technical Specification 3.7.7. Attached is Special Report LER 82-176/99 X-0.

Yours truly,

J.P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8301260382 830121
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22