

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	1	7	7	1	2	1	9	8	2	8	0	1	1	7	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

0 2 | At 0045 during performance of a routine test, it was discovered that #12
0 3 | containment air cooler fan would not shift to low speed (loca speed) or
0 4 | manually start in slow speed from the control room. The cooler was de-
0 5 | clared inoperable and placed out of service per T.S. 3.6.2.2. The three
0 6 | redundant coolers and containment spray system remained operable during
0 7 | the event. Repairs were made, the cooler was tested successfully at 0130,
0 8 | terminating the event. Similar events: 50-317/80-33.

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
0	9	S	B	E	B	R	E	L	A	Y	X	A	Z				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17		8	2	076		23		L		0							
21		22		23		24		25		26							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
C	F	Z	Z	0000		N		0000		Y		A		R389			
13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28		

1 0 The cause for this event was the motor's low speed control relay con-
1 1 tacts not making proper contact; contacts pitted. The relay (Roman Con-
1 2 trol Corp. Model #FE44AA) was replaced. Presently, an engineering review
1 3 is being conducted for a replacement relay. Subject relay will be re-
1 4 placed in all containment cooling fan units.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	E	28	1	0	0	29	N/A	B	31	Surveillance Testing
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	33	Z	34	N/A	44	N/A	36		
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	N/A			
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0	40	N/A					
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z	42	N/A							
PUBLICITY		ISSUED		DESCRIPTION							
2	0	N	44	N/A							

8301260386 830117
PDR ADOCK 05000317
S PDR

NRC USE ONLY

PHONE: (301) 269-4742/4713