



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

January 14, 1983

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-074/03L-0
ER 100450 FILE 841-23
PLA- 1486

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-074/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the sodium pentaborate concentration in the Standby Liquid Control Tank was not within allowable specifications.

H.W. Keiser
Superintendent of Plant-Susquehanna

DGM/cw

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8301260412 830114
PDR ADOCK 05000387
S PDR

122