

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	-	0	3	2	4	7	1	2	1	7	8	2	8	0	1	1	4	8	3	9
60	61									68	69					74		75						80
DOCKET NUMBER											EVENT DATE						REPORT DATE							

0 2 During plant operation, while performing routine nitrogen makeup to the primary con-

0 3 tainment, it was discovered that the CAC system 1" drywell nitrogen inlet PCIV,

0 4 2-CAC-V48, leaks by the closed valve seat. In order to isolate V48, the Unit No. 2

0 5 CAD system primary containment inlet valves, 2-CAC-V55 and V56, were closed and

0 6 deactivated, which rendered the CAD system to Unit No. 2 inoperable. This event did

0 7 not affect the health and safety of the public.

7 8 9 80

SYSTEM CODE S D 11		CAUSE CODE E 12		CAUSE SUBCODE X 13		COMPONENT CODE V A L V E X 14		COMP. SUBCODE E 15		VALVE SUBCODE D 16	
LER/RO REPORT NUMBER 8 2 21 22		EVENT YEAR 8 2 21 22		SEQUENTIAL REPORT NO. 1 3 2 24 26		OCCURRENCE CODE 2 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN X 18		FUTURE ACTION X 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23	
NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER Z 25		COMPONENT MANUFACTURER Z 9 9 9 26							

1 0 The cause of this event is presently undetermined. Within 35 minutes of this event, a

1 1 blank flange was installed in the immediate downstream piping of V48 which reestablished

1 2 primary containment integrity and allowed the return of the CAD system to operable

1 3 status. Plant Engineering is presently evaluating this event to determine an

1 4 applicable fix of the V48 problem.

8 9
FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)

1 5 E 1 0 0 NA A Operational Event

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z Z NA NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES NUMBER (37) TYPE (38) DESCRIPTION (39)

1 7 0 0 0 Z NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL INJURIES NUMBER (40) DESCRIPTION (41)

1 8 0 0 0 NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

LOSS OF OR DAMAGE TO FACILITY TYPE (42) DESCRIPTION (43)

1 9 Z NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PUBLICITY ISSUED (44) DESCRIPTION (45)

2 0 N NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

8301260423 830114
PDR ADOCK 05000324
S PDR

NRC USE ONLY

68 69 70

PHONE: 919-457-9521