

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | S | G | G | S | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | 5

7 8 9 14 15 25 26 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58

LICENSE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 0 9 1 5 8 2 8 0 1 2 0 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During routine surveillance in preparing for non-nuclear heatup (Reactor Recirculation
0 3 | Pump for Heatup), it was discovered that Steam Tunnel Fire Door 1A230 was open with
0 4 | no fire watch established as required by T.S.3.7.7. The door could not be closed due
0 5 | to cables (being used for maintenance activity in the steam tunnel) installed in the
0 6 | doorway. The event had no effect on the health and safety of the public and did not
0 7 | constitute a threat to plant safety. This is a final report.

0	8		80
7	8	9	

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
09		A	B	A	C	X	X	X	X	X	X	Z	Z				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32		
82		82		075		99		X		1							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER			
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48		
H	Z	Z	Z	0	0	0	0	N	N	N	Z	Z	9	9	9		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The fire door was open to allow performance of maintenance work in the steam tunnel.

1 1 | An hourly fire watch was established as required by T.S.3.7.7. The fire watch was

1 2 | maintained for 13 days, 21 hours until the work was complete and the door was secured.

1 3 | A memo was distributed to plant personnel reiterating required compliance to plant

1 4 | procedures and rules on this matter.

7 8 9
FACILITY STATUS (28) 1 5 B
% POWER (29) 0 0 0
OTHER STATUS (30) NA
METHOD OF DISCOVERY (31) B
DISCOVERY DESCRIPTION (32) NA

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 Z (33) Z (34) NA
2 9 0 10 11 44

LOCATION OF RELEASE (36)
NA
45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	000	40	NA

7		8		9		11		12	
LOSS OF OR DAMAGE TO FACILITY									
TYPE		DESCRIPTION							
1	9	Z	42	NA					

7 8 9 10
PUBLICITY
ISSUED DESCRIPTION (45)
2 0 N (44)
8301260434 830120
PDR ADOCK 05000416
S PDR
NRC USE ONLY
68 69 80

NAME OF PREPARER Original signed by Ron Byrd

PHONE: _____