



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

December 29, 1982

2CAN128220

Mr. Norman M. Haller, Director
Office of Management & Program Analysis
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

SUBJECT: Arkansas Nuclear One - Unit 2
Docket No. 50-368
License No. NPF-6
Monthly Operating Report
(File: 2-0520.1)

Gentlemen:

Our Monthly Operating Report submitted December 15, 1982, (by letter 2CAN128211) contained typos in the operating summary. Attached is a corrected operating summary to replace the incorrect summary.

Very truly yours,

John R. Marshall
Manager, Licensing

JFM: SAB: sc

Attachment

cc: Mr. John T. Collins
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Mr. Richard C. DeYoung
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555

IE24

8301270228 821229
PDR ADOCK 05000368
R PDR

NRC MONTHLY OPERATING REPORT
OPERATING SUMMARY - NOVEMBER 1982
UNIT II

Unit 2 began the month in Mode 5 continuing outage #82-11 for refueling. On November 10 the reactor was brought critical for low power physics testing and was tripped on November 12 for more testing. The reactor was returned to criticality on November 12 for continued physics testing. On November 15, the reactor tripped from .79% power when power supply (PS-12) in "B" Channel PPS failed. On November 16 the unit was placed on line; however, later that day the reactor tripped on high steam generator level. The unit was placed back on line. On November 18 the unit was tripped during cooldown for work on incore detectors and a MSR safety valve. On November 22 the unit was tied on line and reached 50% power on November 23. Power was maintained at 50% for physics testing until November 27 when the unit tripped on low DNBF. The unit was returned to power later that day and operated at 50% power through the end of the month.

8301270237 82:229
PDR ADOCK 05000368
R PDR