



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-83-42

January 24, 1983

J. Keppler, Regional Administrator
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Reference: Quad-Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One
Appendix A, Section 3.1.A

Enclosed please find Reportable Occurrence Report Number RO 83-03/03L-0
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.a; Reactor Protection System instrument
setpoint found less conservative than Technical Specification limits,
but which does not affect the performance of the system's function.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

L. J. Hower for
N. J. Kalivianakis

Station Superintendent

NJK:HGL/bb

Enclosure

cc T. J. Rausch
N. Chrissotimos
INPO Records Center

8302040171 830124
PDR ADDCK 05000254
S PDR

JAN 31 1983

IE 22