

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: 

--	--	--	--	--	--

1

7	0	1	8	9	I	L	Q	A	D	I	14	2	0	0	0	-	0	0	0	-	0	0	0	25	3	4	1	1	1	1	30	4		57	CAT	58	5
				LICENSEE CODE										LICENSE NUMBER										LICENSE TYPE													

CONT

0	1
---	---

7 8

REPORT SOURCE

L	6	0	5	0	0	0	2	5	4	7	0	1	1	8	0	3	8	0	1	2	4	0	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 68 69 74 75 80

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing the High, Low, and Low-Low Reactor Water Level Calibration,  
0 3 procedure QIS 10-1, Reactor low water level switch, LIS-1-263-50A, was found to trip  
0 4 at a level 0.62 inches below the Technical Specification 3.1.A. The remaining  
0 5 three switches in the trip logic were found to be calibrated properly.  
0 6 Consequently, a Reactor scram would have occurred at +0 inches Reactor water level  
0 7 and safe plant operation was not affected.

08 |-----| 80

09		SYSTEM CODE 1A		CAUSE CODE E		CAUSE SUBCODE E		COMPONENT CODE INSTRU						COMP. SUBCODE S		VALVE SUBCODE Z																								
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
LER/RO REPORT NUMBER		EVENT YEAR		SHUTDOWN METHOD		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.		ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER												
17		83		Z		003		03		L		0		E		Z		Z		0000		11		Y		11		Y010												

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of this occurrence was instrument setpoint drift. Level switch LIS-1-263-

1 1 50-A was immediately recalibrated with an as-left trip setting of 10.00 inches and

1 2 functionally tested satisfactorily.

13

7 8 9 80

FACILITY STATUS (28) 1 5 E 7 8 9  
% POWER (29) 0 9 9 10 11 12 13  
OTHER STATUS (30) NA 44  
METHOD OF DISCOVERY (31) B 45 46  
DISCOVERY DESCRIPTION (32) Scheduled Surveillance 80

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 33 4 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35)

NA

44

LOCATION OF RELEASE (36)

NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
000	NA

1		2		3		4		5		6		7		8		9		10		11		12	
LOSS OF OR DAMAGE TO FACILITY																							
TYPE		DESCRIPTION																					
1	9	Z	(42)	NA																			
8302040189 830124																							

2 0 ISSUED (44) PUBLICATION DESCRIPTION (45) PDR AD0CK 05000254 S PDR NRC USE ONLY

PHONE: 309-654-2241, ext 133