

ATTACHMENT

MARKED-UP TECHNICAL SPECIFICATION PAGES

<u>Page</u>	<u>Specification</u>	<u>Change Description</u>
3/4 8-7	Table 4.8-1	Renumber the referenced SR 4.8.1.1.2.d to SR 4.8.1.1.2.f

TABLE 4.8-1
DIESEL GENERATOR TEST SCHEDULE

<u>Number of Failures in Last 20 Valid Tests*</u>	<u>Number of Failures in Last 100 Valid Tests*</u>	<u>Test Frequency</u>
<u><1</u>	<u><4</u>	Once per 31 days
<u>≥2**</u>	<u>≥5</u>	Once per 7 days

*Criteria for determining number of failures and number of valid tests shall be in accordance with Regulatory Position C.2.e of Regulatory Guide 1.108, but determined on a per diesel generator basis.

For the purposes of determining the required test frequency, the previous test failure count may be reduced to zero if, in conjunction with the manufacturer a complete diesel overhaul to like-new conditions is completed, and if acceptable reliability has been demonstrated. The reliability criterion shall be the successful completion of 14 consecutive tests in a single series. Ten of these tests shall be in accordance with Surveillance Requirement 4.8.1.1.2.a.3 and 4.8.1.1.2.a.4; four tests, in accordance with Surveillance Requirement ~~4.8.1.1.2.d~~. If this criterion is not satisfied during the first series of tests, any alternate criterion to be used to transvalue the failure count to zero requires NRC approval.

4.8.1.1.2.f

**The associated test frequency shall be maintained until seven consecutive failure free demands have been performed and the number of failures in the last 100 valid demands has been reduced to one.