

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001c Low Volume Waste
Regen. Wastes Soln. Dischg. Tank

PARAMETER AND PERMIT LIMIT: TSS, 15 mg/l
Total Iron, 1.0 mg/l

NONCOMPLIANCE, DATE, AND DURATION: TSS, 56 mg/l, 3JAN83, 2½ hrs.
Total Iron, 2.5 mg/l, 3JAN83, 2½ hrs.

CAUSE OF NONCOMPLIANCE:

Possible causes of these noncompliances are wastes from Unit 2 Condensate Polishing System regeneration, and a buildup of solids in the discharge tank.

CORRECTIVE ACTION:

A modification has been initiated to provide the option for treatment of these tanks in the wastewater treatment facility. The modification should be implemented by February 1983. Further investigation into whether solids are building up in the Discharge Tank is in progress.

DATE RECOGNIZED AS A VIOLATION:

6JAN83

DATE INVESTIGATED:

10JAN83