



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 4, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Detection Zone 2-2
Alarmed and Would Not Reset
LER 83-017/03 L-0
AECM-83/85

On January 7, 1983, fire detection zone 2-2 alarmed with no smoke or flames present and would not reset. The alarm was deactivated and an hourly fire watch was established in accordance with Technical Specification 3.3.7.9. This is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-017/03 L-0.

Yours truly,

For J.P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302140014 830204
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

LE 22