



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 4, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Shutdown Cooling Loop B
Removed From Service in
Order to Perform Planned
Maintenance
LER 83-015/03 L-0
AECM-83/82

On January 5, 1983, while in cold shutdown, Shutdown Cooling Loop B was removed from service and declared inoperable to perform planned maintenance. An alternate method of decay heat removal was demonstrated in accordance with Technical Specification 3.4.9.2. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-015/03 L-0.

Yours truly,

L. P. Doherty
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. I. [unclear] (w/a)
Mr. R. B. [unclear] (w/a)
Mr. T. B. [unclear] (w/a)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302140031 830204
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22