

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/1/0/8/8/3/ (8) /0/2/0/1/8/3/ (9)
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On January 8, 1983, with Unit 2 in Mode 1 the Valve Monitoring System Cabinet was/
/0/3/ / deenergized for maintenance. This caused a loss of valve position indication for/
/0/4/ / Unit 2 pressurizer safeties and power operated relief valves. Since discharge /
/0/5/ / line temperature indication was available to verify valve position and limit /
/0/6/ / switch indication was available for the power operated relief valves the health /
/0/7/ / and safety of the public were not affected. This event is contrary to T.S. /
/0/8/ / 3.3.3.6 and reportable pursuant to T.S. 6.9.1.9.b. /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE

/0/9/ /I/D/ (11) /X/ (12) /Z/ (13) /Z/Z/Z/Z/Z/Z/ (14) /Z/ (15) /Z/ (16)
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
REPORT NO. CODE TYPE NO.

(17) NUMBER /8/3/ /-/ /0/0/5/ /-/ /0/3/ /L/ /-/ /0/

ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER

/X/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /Z/ (25) /Z/Z/Z/Z/
(26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / Normal and backup supply breakers to Valve Monitoring System, Cabinet 1-EI-CB- /
/1/1/ / 190, were opened so that maintenance could be performed on a remote valve indica- /
/1/2/ / tor for SV-2551A. After maintenance was performed the breakers were closed and /
/1/3/ / power returned to the cabinet. Valve indication was lost for approximately 10 /
/1/4/ / minutes. 1-EI-CB-190 is common to Units 1 & 2. /

FACILITY METHOD OF
STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
/1/5/ /E/ (28) /0/3/0/ (29) / NA / (30) /A/ (31) / Operator Observation /

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)
/1/7/ /0/0/0/ (37) /Z/ (38) / NA /

PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
/1/8/ /0/0/0/ (40) / NA /

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
/1/9/ /Z/ (42) / NA /

PUBLICITY
ISSUED DESCRIPTION (45)
/2/0/ /N/ (44) / NA /

NRC USE ONLY

NAME OF PREPARER W. R. CARTWRIGHT

PHONE (703) 894-5151

8302140047 830201
PDR ADOCK 05000339
S PDR