



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 3, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Door OC520 Blocked Open
to Facilitate Planned
Maintenance in the Area
LER 83-007/03 L-0
AECM-83/77

On January 7, 1983, Fire Door OC520 was temporarily blocked open to facilitate planned maintenance in the area. Fire watches were posted in accordance with Technical Specification 3.3.7.9. This report is submitted in accordance with Technical Specification 6.9.1.13.b. Attached is LER 83-007/03 L-0.

Yours truly,

J. P. McGaughy
for J. P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302140058 830203
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

TE 22