



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 3, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Rated Barriers in the  
Control Building and  
Auxiliary Building Opened  
to Perform Planned  
Maintenance Activities  
LER 83-011/99 X-0  
AECM-83/79

From January 3 to January 24, 1983, certain fire rated barriers in the Control Building and Auxiliary Building were opened to perform planned maintenance activities. Fire watches were established in accordance with Technical Specification 3.7.7.a. Attached is Special Report LER 83-011/99 X-0.

8302140063 830203  
PDR ADOCK 05000416  
S PDR

Yours truly,

  
for J. P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555