



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 11, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Update to Previous Report -  
Incorrect Setpoints for RHR  
Injection Valve  
Differential Pressure  
Switches  
LER 82-059/01 X-1  
AECM-83/0091

This letter submits an update to a previous report submitted on September 22, 1982. The event for which the report was made occurred on September 9, 1982, when it was discovered that the differential pressure switches for the RHR injection valves were incorrectly set during the performance of routine leakage tests. The pressure switches were found to be set at 58 psig rather than less than or equal to 50 psig as required by Technical Specification 4.4.3.2.3.

All corrective action for this event had been completed at the time of the previous report and reported then. A Surveillance Procedure Review was initiated and discussed in the previous report, however, the results of the review will not be made in connection with this report. A separate report will be submitted upon completion of the review. Attached is LER 82-059/01 X-1, which is a final report.

Yours truly,

*Jeff L. Anderson*  
FOR J. P. McGAUGHY JR.

8302170346 830211  
PDR ADDCK 05000416  
S PDR

JPM:sap  
Attachment

cc: (See Next Page)

OFFICIAL COPY

Member Middle South Utilities System

LE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0091

Page 2

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555