

# LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE L 6 0 5 0 0 0 3 6 1 7 0 1 0 8 8 3 8 0 2 0 8 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

With Units 2 and 3 in Modes 1 and 4, respectively, Emergency Chiller E-336 failed to

start and was declared inoperable. This rendered all equipment inoperable in rooms in

both Units 2 and 3 where chilled water is provided to cool ambient air in the event of

a Toxic Gas Isolation Signal (TGIS), Safety Injection Actuation Signal (SIAS) or loss of

offsite power. There was no impact on plant operation or the health and safety of

plant personnel or the public as a result of this occurrence, since normal HVAC was

operating throughout the event.

7 8

SYSTEM CODE [A][A] 11

CAUSE CODE [E] 12

CAUSE SUBCODE [G] 13

COMPONENT CODE [I][N][S][T][R][U] 14

COMP. SUBCODE [X] 15

VALVE SUBCODE [Z] 16

17 LER RO REPORT NUMBER [8][3] 21 22

EVENT YEAR [8][3] 21 22

SEQUENTIAL REPORT NO. [0][1][2] 24 25 26

OCCURRENCE CODE [0][3] 28 29

REPORT TYPE [L] 30

REVISION NO. [0] 32

ACTION TAKEN [A] 18 19

FUTURE ACTION [Z] 19

EFFECT ON PLANT [Z] 20

SHUTDOWN METHOD [Z] 21

HOURS [0][0][0][0] 22 37 38 39 40

ATTACHMENT SUBMITTED [Y] 23

NPRO-4 FORM SUB. [N] 24

PRIME COMP. SUPPLIER [A] 25

COMPONENT MANUFACTURER [C][1][4][7] 26 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Chiller failure was due to a faulty program timer. The timer was replaced and the

Chiller and all associated equipment were declared operable at 1500 on January 9,

1983. This was an isolated occurrence and no further corrective action is

planned.

1	4											80
7	8											80
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION				80
1	5	8	28	0	5	0	29	NA	B	31	Testing	32
7	8											80
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE				80
1	6	2	33	2	34	NA	35	NA				35
7	8											80
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION						80
1	7	0	0	0	37	2	38	NA				39
7	8											80
PERSONNEL INJURIES		NUMBER		DESCRIPTION								80
1	8	0	0	0	40	NA	41					42
7	8											80
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION								80
1	9	Z	42			NA	43					44
7	8											80
PUBLICITY		ISSUED		DESCRIPTION								80
2	0	N	44			NA	45					46
7	8											80
NRC USE ONLY												

NRC USE ONLY

HB Ray / NY March