

Filed: February 11, 1983

RELATED CORRESPONDENCE

DOCKETED
USNRC

'83 FEB 17 10:53

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
before the
ATOMIC SAFETY AND LICENSING BOARD

In the Matter of

PUBLIC SERVICE COMPANY OF NEW
HAMPSHIRE, et al.

(Seabrook Station, Units 1 & 2)

Docket Nos. 50-443 OL
50-444 OL


APPLICANTS' EIGHTH MOTION FOR
SUMMARY DISPOSITION
(CONTENTION NECNP I.A.2)

Pursuant to 10 CFR § 2.749, the Applicants hereby
move for summary disposition of contention NECNP I.A.2.

This motion is submitted upon the affidavit of John
M. O'Connor attached hereto. As set forth therein all
inside containment Class 1E electric valve operators
will be qualified pursuant to Reg. Guides 1.73 (Rev. 0,
1/74), and 1.89 (Rev. 0, 11/74) and NUREG-0588.

Qualification pursuant to the guidance offered in these documents constitutes one acceptable method of complying with GDC 4. Thus summary disposition in favor of the Applicants is in order.

Respectfully submitted,

Thomas G. Dignan, Jr.
R. K. Gad III
Ropes & Gray
225 Franklin Street
Boston, Massachusetts 02110
Telephone: 423-6100

Dated: February 11, 1983

STATEMENT OF MATERIAL FACTS
AS TO WHICH THERE IS NO DISPUTE

1. All Class 1E electric valve operators installed inside containment will be qualified in conformity with Reg. Guide 1.73 (Rev. 0, 1/74); Reg. Guide 1.89 (Rev. 0, 11/74) and NUREG-0588.