

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001c Low Volume Waste
Regen. Wastes Soln. Discharge Tk.

PARAMETER AND PERMIT LIMIT: Total Suspended Solids, 15 mg/l

NONCOMPLIANCE, DATE, AND DURATION: 18 mg/l, 18JAN83, 4-1/3 hours

CAUSE OF NONCOMPLIANCE:

Possible causes of this noncompliance are wastes from Unit 2 condensate polishing system regeneration, and a buildup of solids in the discharge tank.

CORRECTIVE ACTION:

A modification has been initiated to provide the option for treatment of these tanks in the wastewater treatment facility. The modification should be implemented by February 1983. Further investigation into whether solids are building up in the discharge tank is in progress.

8302180467 830207
PDR ADOCK 05000373
S PDR

DATE RECOGNIZED AS A VIOLATION:

20JAN83

DATE INVESTIGATED:

24JAN83