

RELATED CORRESPONDENCE

DOCKETED
USNRC

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
before the

'83 FEB 17 A10:57

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

ATOMIC SAFETY AND LICENSING BOARD

In the Matter of
PUBLIC SERVICE COMPANY OF NEW
HAMPSHIRE, et al.
(Seabrook Station, Units 1 & 2)

Docket Nos. 50-443 OL
50-444 OL

APPLICANTS' FOURTEENTH MOTION FOR
SUMMARY DISPOSITION
(CONTENTION NECNP I.D.3)

Pursuant to 10 CFR § 2.749, the Applicants hereby
move for summary disposition of contention NECNP I.D.3.

This motion is submitted upon the affidavit of
William N. Fadden, attached hereto. As therein set
forth the Applicant fully complies with Reg. Guide 1.45
which in turn constitutes an acceptable method of
compliance with GDC 30.


8302180487 830211
PLN ADOCK 05000443
G PDR

DS03

GDC 21 has no applicability to the leakage detection system, because it is not part of the Reactor Protection System.

Thus summary disposition of NECNP I.D.3 is now in order, there being no triable issue of fact.

Respectfully submitted,

A handwritten signature in dark ink, appearing to read "T. G. Dignan, Jr.", with a large, sweeping flourish extending to the right.

Thomas G. Dignan, Jr.
R. K. Gad III
Ropes & Gray
225 Franklin Street
Boston, Massachusetts 02110
Telephone: 423-6100

Dated: February 11, 1983

STATEMENT OF MATERIAL FACTS
AS TO WHICH THERE IS NO DISPUTE

1. The Applicants are in full compliance with Reg. Guide 1.45.
2. The Reactor Coolant Pressure Boundary Leakage Detection System is not part of the Reactor Protection system.