



Log # TXX-94032
File # 916 (3/4.7)
10010
Ref. # 10CFR50.90
10CFR50.36

William J. Cahill, Jr.
Group Vice President

February 23, 1994

U. S. Nuclear Regulatory Commission
Attn: Document Control Room
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
LICENSE AMENDMENT REQUEST 93-003
SUPPLEMENTAL INFORMATION

REF: TU Electric letter logged TXX-93190, dated
May 21, 1993, from William J. Cahill, Jr. to
the USNRC

Gentlemen:

By the above reference, TU Electric provided license amendment request 93-003 to the NRC regarding the Control Room HVAC System including Control Room Air Conditioning System (CRACS). Following review and subsequent discussions between the NRC staff and TU Electric personnel, the following supplemental information is provided:

- 1) Add "immediately" to the Action Statements for MODES 5 and 6 in specifications 3.7.7.1 and 3.7.7.2, to be consistent with NUREG-1431; and
- 2) Revise the Action Statements for two trains inoperable in specification 3.7.7.2 and BASES to require "at least 100% of the required heat removal capability equivalent to a single OPERABLE CRACS train available", to be consistent with NUREG-1431, Section 3.5.2.

The above changes are reflected in the attached mark-up (See Attachment 2). This supplemental information clarifies the meaning of the original license amendment request and does not change its intent or technical meaning.

280066

9403040292 940223
PDR ADDCK 05000445
P PDR

1029
11

TXX-94032
Page 2 of 2

Should you have any questions, please contact Mr. Manu C. Patel at
(214) 812-8298.

Sincerely,



William J. Cahill, Jr.

MCP/grp

Attachments: 1. Affidavit
 2. Affected Technical Specification pages (NUREG-1468)


c - Mr. L. J. Callan, Region IV
 Mr. L. A. Yandell, Region IV
 Resident Inspectors, CPSES (2)
 Mr. T. A. Bergman, NRR

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)	
)	
Texas Utilities Electric Company)	Docket Nos. 50-445
)	and 50-446
(Comanche Peak Steam Electric)	
Station, Unit 1 & 2))	


AFFIDAVIT

William J. Cahill, Jr. being duly sworn, hereby deposes and says that he is Group Vice President, Nuclear Production of TU Electric, the licensee herein; that he is duly authorized to sign and file with the Nuclear Regulatory Commission this supplemental information to License Amendment Request 93-003 to the CPSFS Unit 1 Operating License (NPF-87) and CPSES Unit 2 Operating License (NPF-89); and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.


William J. Cahill, Jr.
Group Vice President, Nuclear

STATE OF TEXAS)
)
COUNTY OF SOMERVELL)

Subscribed and sworn to before me, on this 23rd day of February, 1994.


Notary Public

