

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	6	4	7	0	1	2	1	8	3	8	0	2	1	7	8	3	9
60	61									68	69						74	75						80

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1600 on 1/21/83, while attempting to increase the accumulator nitrogen pressure,
03 | Containment Isolation Valve Q2E21HV8880 (Nitrogen Supply to Accumulator Isolation)
04 | was declared inoperable when it would not fully open. Tech. Spec. 3.6.3, in part,
05 | requires this valve to be operable. Tech. Spec. 3.6.3 action statement requirements
06 | were met. Health/safety of the public was not affected.
07 |
08 |

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	S	D	E	B	V	A	L	V	E	X	F	D				
		9	10	11	12	13	18				19	20					
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
83		83		002		03		L		0							
21		22		24		28		30		32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
A	Z	Z		Z		0000		N		N		N		C635			
22	23	24		25		26		27		28		29		30		31	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was due to the valve binding between the cage and plug assembly. The

1 1 cage and plug assembly were replaced. Following the satisfactory performance of

1 2 FNP-2-STP-10.3 (Emergency Core Cooling Valves Inservice Test) and FNP-2-STP-627

1 3 (Local Leak Rate Testing of Containment Penetrations). Containment Isolation Valve

1 4 Q2E21HV8880 was declared operable at 0110 on 1/22/83.

FACILITY STATUS												% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION											
1	5	E		28	1	0	0	29	NA				A	31	Operational Event																				
ACTIVITY CONTENT												RELEASED OF RELEASE				AMOUNT OF ACTIVITY				LOCATION OF RELEASE															
1	6	Z		33	Z	34	NA				NA																								
PERSONNEL EXPOSURES												NUMBER				TYPE				DESCRIPTION															
1	7	0		0	0	37	Z	38	NA																										
PERSONNEL INJURIES												NUMBER				DESCRIPTION																			
1	8	0		0	0	40	NA																												
LOSS OF OR DAMAGE TO FACILITY												TYPE				DESCRIPTION																			
1	9	Z		42	NA																														
PUBLICITY												ISSUED				DESCRIPTION																			
2	0	N		44	NA																														

8302280042 830217
 PDR ADOCK 05000364
 S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156