

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 F L S L S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 27 CAT 28

CON'T

01 REPORT SOURCE L 0 5 0 0 0 3 3 5 7 0 1 2 8 8 3 3 0 2 1 8 8 3 9

DOCKET NUMBER 30 31 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 WHILE TESTING THE OPERABILITY OF THE CONTAINMENT FAN COOLERS USING A

03 STAGGERED TEST BASIS, HVS-1D FAILED TO START. THE OTHER THREE FAN

04 COOLERS WERE RUNNING AT THE TIME. THE NONOPERABLE FAN COOLER WAS

05 REPAIRED AND RETURNED TO OPERABILITY AFTER ONE HOUR. THIS IS WELL

06 WITHIN THE TIME LIMIT REQUIRED BY TS 3.6.2.3a. THE HEALTH AND SAFETY

07 OF THE PUBLIC WERE NOT AFFECTED. THIS IS FIRST EVENT OF THIS TYPE.

08

09

SYSTEM CODE S B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE C K T B R K 14 COMP TUBCODE A 15 VALVE SUBCODE Z 16

LEAD REPORT NUMBER 17 EVENT YEAR 8 3 SEQUENTIAL REPORT NO. 0 0 8 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN B 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. Y 24 PRIME COMP SUPPLIER A 25 COMPONENT MANUFACTURER I 0 0 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE FAN DID NOT START DUE TO DIRTY BREAKER CONTACTS AT THE LOAD CENTER

11 BREAKER. THE BREAKER WAS OVERHAULED AND THOROUGHLY CLEANED. THIS BREAKER

12 IS INCORPORATED IN A REGULAR CLEANING AND MAINTENANCE SCHEDULE.

13

14

FACILITY STATUS E 28 % POWER 0 9 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED DESCRIPTION N 44 NA 45

NAME OF PREPARER S. A. Valdes PHONE (305) 465-3426

8302280047 830218
PDR ADOCK 05000335
S PDR

NRC USE ONLY