



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 22, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Meteorological
Monitoring System Removed
from Service
LER 82-145/03 X-1
AECM-83/0112

This letter submits an update to a previous report submitted on December 22, 1982. The event for which the report was made occurred on November 27, 1982, when the Meteorological Monitoring System was removed from service for approximately 7.5 hours to perform work as required by design change package 82-457. The event was reported pursuant to Technical Specification 6.9.1.13.b.

This update report is submitted to correct an error made in LER 82-145/03 L-0. The statement was made that "DCP 82-457 was implemented to change breakers and circuit wires to meet NRC requirements". The statement should have said "DCP 82-457 was implemented to change breakers and circuit wires to meet National Electrical Code (NEC) requirements." Attached is corrected LER 82-145/03 X-1.

Yours truly,


FOR J. P. McGaughy, JR.

JPM:sap
Attachment

cc: (See Next Page)

8302280071 830222
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

LE 22

83 FEB 23 AID: 08

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. N. L. Stampley (w/a)
 Mr. R. B. McGehee (w/o)
 Mr. T. B. Conner (w/o)
 Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
 Office of Inspection & Enforcement
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555

Document Control Desk (w/a)
 U. S. Nuclear Regulatory Commission
 Washington, D. C. 20555