

CONTROL BLOCK: 

1	2	3	4	5	6
---	---	---	---	---	---

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[illegible]

CON'T

0 1 7 8  
REPORT SOURCE L 6 0 1 5 0 0 0 3 6 6 7 0 1 2 8 8 3 8 0 2 1 7 8 3 9  
60 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 1/28/83, during performance of a routine panel walkdown, operating  
0 3 | personnel discovered that the position indicating light for the 2A  
0 4 | recirculation pump discharge valve was not illuminated. This made the  
0 5 | valve inoperable which is contrary to Tech. Specs. section 3.4.1.1.  
0 6 | Plant operation was continued per Tech. Specs. section 3.4.1.1,  
0 7 | ACTION a. The health and safety of the public were not affected by  
0 8 | this non-repetitive event.

SYSTEM CODE C B 11		CAUSE CODE C 12		CAUSE SUBCODE X 13		COMPONENT CODE V A L V E X 14		COMP. SURCODE A 15		VALVE SUBCODE D 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 3 21 22		SEQUENTIAL REPORT NO. 0 0 5 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 22		ATTACHMENT SUBMITTED N 23	
NPRD 4 FORM SUB. N 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER L 3 0 0 26							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 An expeditious investigation revealed that the valve's electrical

1 1 circuit breaker was in the "OFF" position (for unknown reasons). The

1 2 circuit breaker was placed in the "ON" position. The indicator light

1 3 then illuminated. This returned the valve to operable status.

1 4 7 8 9 FACILITY STATUS 30 % POWER 0 7 0 29 OTHER STATUS 32 METHOD OF DISCOVERY 31 Operator Observation 45 46 80

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 [Z] (33) [Z] (34) NA 44

LOCATION OF RELEASE (36)

NA 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA	80			

PERSONNEL INJURIES		DESCRIPTION	(41)
NUMBER			
1	2	0 0 0 0 (40)	NA
			80

7	8	9	11	12	8302280138	830217
LOSS OF OR DAMAGE TO FACILITY					(43)	PDR ADCK 05000366
TYPE DESCRIPTION					NA	PDR

7	8	9	10	PUBLICATION										NRC USE ONLY											
ISSUED			DESCRIPTION																						

2 0 N (44) NA 68 69  
7 8 9 10  
S. B. Tipps PHONE: (912) 367-7851