

50-400, 401



Carolina Power & Light Company

P. O. Box 101, New Hill, N. C. 27562
February 17, 1983

83 FEB 23 AG: 52

INFO RECD

Mr. James P. O'Reilly
United States Nuclear Regulatory Commission
Region II
101 Marietta Street, Northwest (Suite 3100)
Atlanta, Georgia 30303

NRC-43

CAROLINA POWER & LIGHT COMPANY
SHEARON HARRIS NUCLEAR POWER PLANT
1986-90 - 900,000 KW - UNITS 1 & 2
EMERGENCY DIESEL GENERATOR ENGINE ANCHOR BOLTS & NUTS, ITEM 114

Dear Mr. O'Reilly:

On January 17, 1983, Mr. A. Hardin was notified of a potentially reportable item per provisions of 10CFR50.55(e) and 10CFR, Part 21. The emergency diesel generator engine anchor bolts and nuts supplied by Transamerica DeLaval, Inc. were not identifiable by type and grade, since the markings stamped on the bolts and nuts were not consistent with industry standards. At the present time, these discrepancies are still under evaluation, which is expected to be complete by March 30. For this reason, we request an extension until April 15, 1983 for submitting a report on the item's reportability.

Thank you very much for your consideration in this matter.

Yours very truly,

R. M. Parsons
Project General Manager
Shearon Harris Nuclear Power Plant

RMP/sh

cc: Mr. G. Maxwell (NRC-SHNPP)
Mr. V. Stello (NRC)

OFFICIAL COPY

IE 27