

APPROVED BY OMB  
3150-0011  
EXPIRES 4-30-82

CONTROL BLOCK: 

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	S	C	V	C	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	0	0	0	4			5	
7	8	9					14		15											25		26				30		57	CAT	58
LICENSE CODE								LICENSE NUMBER												LICENSE TYPE										

CON'T

0	1	REPORT SOURCE	I	6	0	5	0	0	0	3	9	5	7	0	1	2	4	8	3	8					9
7	8		60	61	DOCKET NUMBER								68	EVENT DATE				74	REPORT DATE				80		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On January 24, 1983 with the Plant in Mode 1, the NRC Resident Inspector  
0 3 | identified a discrepancy of 9% between the Main Control Board and Control  
0 4 | Room Evacuation Panel (CREP) indication for Pressurizer Relief Tank Level.  
0 5 | There were no adverse consequences from this event. The level indication was  
0 6 | functional but drifted high during the period of time between January 3 through  
0 7 | 24, 1983.  
0 8 |

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE		COMP. SUBCODE		VALVE SUBCODE	
0	9	I	D	E		I	N	S	T	R	U
7	8	9	10	11	12	13	14	15	16	17	18
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
		8	3	007		/	03	L	-	0	
		21	22	23	24	25	26	27	28	29	30
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD		HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER
E	C	Z	Z		0000	Y	N		A		R369
33	34	35	36	37	38	39	40	41	42	43	44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the event was instrument drift. The level transmitter for the  
1 1 CREP was calibrated, and the indication channel returned to service on  
1 2 January 24, 1983. Level transmitter (LT-470A) is scheduled for replacement  
1 3 during the next outage. Until the transmitter can be replaced, the indication  
1 4 will be verified operable weekly.

9 9  
FACILITY STATUS      % POWER      OTHER STATUS (30)      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION (32)

1 5 B (28) 0 5 0 (29) N/A D (31) Inspector Observation

10 12 13 44 45 46 60

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) N/A N/A

PERSONNEL EXPOSURE NUMBER		TYPE	DESCRIPTION
1	7	0 0 0	(37) Z (38) N/A (39)

		PERSONNEL INJURIES		
		NUMBER	DESCRIPTION	
1	8	0 0 0	(40) N/A	80

7 8 9 11 12  
LOSS OF OR DAMAGE TO FACILITY  
TYPE DESCRIPTION (43)  
1 9 | 2 | (42) |  
8302280198 830217  
PDR ADOCK 05000395  
S PDR

7 8 9 10

PUBLICITY  
ISSUED DESCRIPTION (45)

N/A

NRC USE ONLY

NAME OF PREPARER C. J. McKinney PHONE: (803) 345-5209

NAME OF PREPARER

C. J. McKinney

PHONE: (803) 345-5209