



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 18, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Rated Door OC104 Blocked  
Open to Route Hose  
LER 83-031/99 X-0  
AECM-83/0100

On January 13, 1983, fire rated door OC104 was blocked open to route a temporary discharge hose from the Hot Machine Shop sump to the Turbine Building floor drain system. An hourly fire watch was established in accordance with Technical Specification 3.7.7. Attached is Special Report LER 83-031/99 X-0.

Yours truly,

*L.P. McGaughy*  
for J.P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8302280294 830218  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22