

## LICENSEE EVENT REPORT

CONTROL BLOCK: 

1	2	3	4	5	6
---	---	---	---	---	---

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1
---	---

 M I D C C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 

5
---

  
7 8 9 14 15 25 26 30 57 CAT 58CON'T  

0	1
---	---

 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 1 1 8 8 3 8 0 2 1 7 8 3 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 DURING NORMAL OPERATION, THE UNIT 2 AUXILIARY CABLE VAULT (ZONE 11) EXPERIENCED

0 3 AN INADVERTANT CO<sub>2</sub> DISCHARGE ( REF: 50-316/83-019). AFTER DETERMINING THAT THE CO<sub>2</sub>

0 4 ACTUATION WAS SPURIOUS, THE CO<sub>2</sub> TANK WAS ISOLATED AT 1625 HOURS TO TERMINATE THE

0 5 DISCHARGE. THE MAIN ISOLATION VALVE WAS USED WHICH ALSO ISOLATED UNIT 1.

0 6 THIS EVENT WAS NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION 3.3.3.8.

0 7 PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.

0	9
---	---

 SYSTEM CODE A B 11 CAUSE CODE X 12 CAUSE SUBCODE E 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LEAD REPORT NUMBER 8 3 21 22 0 2 2 27 0 3 28 29 L 30 31 0 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
X 18 Z 19 Z 20 Z 21 0 0 0 0 0 N 23 N 24 A 25 P 4 3 5 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE CO<sub>2</sub> TANK MAIN ISOLATION WAS ISOLATED WHICH AFFECTS BOTH UNIT 1 AND 2.

1 1 APPROXIMATELY 10 MINUTES LATER THE VALVE ISOLATING THE SPECIFIC AREA OF CONCERN

1 2 WAS CLOSED AND THE MAIN ISOLATION RE-OPENED. NO FURTHER ACTION PLANNED.

1 3

1 4

1	5
---	---

 FACILITY STATUS E 28 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32  
7 8 9 10 12 13 44 45 46 80  

1	6
---	---

 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80  

1	7
---	---

 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 80  

1	8
---	---

 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 80  

1	9
---	---

 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 80  

2	0
---	---

 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 80  
NRC USE ONLY  
68 69 80 91-92

NAME OF PREPARER D. F. KRAUSE

PHONE: (616) 465-5901 Ext. 109