



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 23, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Auxiliary Building Equipment
Hatch Removed to Transport
Neutron Sources into
Containment
LER 83-025/03 L-0
AECM-83/0115

On January 24, 1983, while in cold shutdown, the Auxiliary Building equipment hatch on elevation 166 feet was removed to allow transport of neutron sources into the containment. The plug is classified as a fire barrier under Technical Specification 3.7.7. A Limiting Condition of Operation was established and an hourly fire watch was initiated in accordance with Technical Specification 3.7.7. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-025/03 L-0.

Yours truly,

JPM
for JPM Gaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8302280424 830223
PDR ADDCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IF 22

83 FEB 24 11:00

USNRC REGION
ATLANTA