



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 23, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Supervision System for Fire
Rated Door OC517 Alarmed
and Would Not Reset
LER 83-016/03 L-0
AECM-83/0114

On January 24, 1983, while in cold shutdown, the supervision system for fire rated door OC517 (stairwell entrance, elevation 166 feet, Control Building) alarmed and would not reset with the door closed. The door was declared inoperable and an hourly fire watch was established in accordance with Technical Specification 3.7.7.a. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-016/03 L-0.

Yours truly,

FOR J.P. McGaughy Jr.

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

TE 22

8302280448 830223
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System