

LICENSEE EVENT REPORT

Attachment to AECM-83/0114
Page 1 of 1

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5		
LICENSEE CODE								LICENSE NUMBER												LICENSE TYPE								CAT		58	

CON'T

0	1	L	6	0	5	0	0	0	4	1	6	7	0	1	2	4	3	8	0	2	2	3	8	3	9
REPORT SOURCE		DOCKET NUMBER										EVENT DATE				REPORT DATE									

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On January 24, 1983, while in cold shutdown, the supervision system for fire rated

0 3 door OC517 (stairwell entrance, elevation 166 feet, Control Building) alarmed and

0 4 would not reset with the door closed. The door was declared inoperable and an

0 5 hourly fire watch was established in accordance with T.S.3.7.7.a. The event had no

0 6 effect on the health and safety of the public and did not constitute a threat to

0 7 plant safety. This is reported pursuant to T.S.6.9.1.13.b.

0	9	A	B	11	X	12	Z	13	Z	Z	Z	Z	Z	14	Z	15	Z	16
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE								COMP. SUBCODE		VALVE SUBCODE		

17	8	3	—	0	1	6	—	0	3	L	—	0
LER/RO REPORT NUMBER	EVENT YEAR		—	SEQUENTIAL REPORT NO.		—	OCCURRENCE CODE		REPORT TYPE		—	REVISION NO.

X	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	N	24	Z	25	Z	9	9	9	26
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER								

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 On January 31, 1983, maintenance personnel investigated and found the system operable

1 1 after performing a functional test. Therefore, the door was restored and the fire

1 2 watch was lifted within the seven day time limit. The cause of the alarm was not

1 3 determinable. This is submitted as a final report.

1	5	G	28	0	0	0	29	NA	30	A	31	Alarmed Condition	32
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					

1	6	Z	33	Z	34	NA	35	NA	36
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			

1	7	0	0	0	37	Z	38	NA	39
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					

1	8	0	0	0	40	NA	41
PERSONNEL INJURIES		DESCRIPTION					

1	9	Z	42	NA	43
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION	

2	0	N	44	8302280454	830223	PDR	ADOCK	05000416	PDR
ISSUED		DESCRIPTION		NRC USE ONLY					

NAME OF PREPARER Ron Byrd and Boyd Shingleton

PHONE: