

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
1750 Chestnut Street Tower II

February 22, 1983

83 FEB 24 AM 1:05

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE  
REPORT SQRO-50-327/83014

The enclosed report provides details concerning the hydrogen recombiner  
being inoperable because of a bad kilowatt meter. This report is submitted  
in accordance with Sequoyah unit 1 Technical Specification 6.9.1.15.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
H. J. Green  
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Records Center  
Institute of Nuclear Power Operations  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

NRC Inspector, Sequoyah

8302280457 830222  
PDR ADOCK 05000327  
S PDR

OFFICIAL COPY

IE 22