

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	T	N	S	N	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	LICENSE NUMBER												25	LICENSE TYPE					30	57 CAT		58

CON'T

REPORT SOURCE: 01 L 6 0 5 0 0 0 3 2 7 7 0 1 2 2 8 3 8 0 2 2 2 8 3 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Unit 1 was in mode 1 at 32% power with the RCS temperature and pressure at 556 degree
0 3 | F and 2235 psig. The unit operator observed the kilowatt meter for the hydrogen
0 4 | recombiner was reading off scale high. This required entry into the action statement
0 5 | of LCO 3.6.4.2. There was no effect upon the public health and safety. Previous
0 6 | occurrences - none.

07 | _____

08
7 8 9

0 9 7 8 S E 9 10 (11) E 11 12 (12) G 12 13 (13) R E C O M B 13 14 (14) Z 14 15 (15) Z 15 16 (16)

(17) LER/RO REPORT NUMBER [8 | 3] [21 | 22] [23]
 SEQUENTIAL REPORT NO. [0 | 1 | 4] [24 | 25 | 26] [27]
 OCCURRENCE CODE [0 | 3] [28 | 29]
 REPORT TYPE [L] [30] [31]
 REVISION NO. [0] [32]

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
C	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	N	24	L	25	X	9	9	9
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The kilowatt meter on the hydrogen recombiner was observed to be reading off scale

1 1 | high. The active filter, Halmar Model No. LZFl-271105 failed causing the incorrect

1 2 | reading. The probable cause of failure was aging and can be considered an isolated

1 3 | case. The active filter and control potentiometer were replaced and the system

1 4 | returned to service.

FACILITY STATUS (1) 5 (C) (28) % POWER (0) 3 2 (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) Operator observation

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 2 33 3 34 NA LOCATION OF RELEASE (36)
7 8 9 10 11 44 45

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	37 Z 38 NA 39				

PERSONNEL INJURIES					
NUMBER			DESCRIPTION		
1	8		0	0	0
			(47)		NA

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
19 8 9 10 Z (42) NA

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (44) NA
 8 9 10
 8302280465 830222
 PDR ADOCK 05000327
 S PDR
 NRC USE ONLY

Name of Preparer: W. C. Ludwig /M. R. Harding

Phone: (615) 751-0349