

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK:

--	--	--	--	--	--	--

1

0	1	N	C	B	E	P	Z	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

REPORT
SOURCE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation, performance of the channel calibration and functional test of
0 3 the HPCI System CST suction low water level instrumentation, PT-03.1.2PC, revealed
0 4 CST level low instrument, 2-E41-LSL-N003, did not actuate within the required
0 5 calibration tolerances. In accordance with technical specifications the HPCI system was
0 6 declared inoperable. This event did not affect the health and safety of the public.

Technical Specifications 3.3.3, 3.5.1, 6.9.1.5b

SYSTEM CODE S F		CAUSE CODE E		CAUSE SUBCODE X		COMPONENT CODE I N S T R U				COMP. SUBCODE S		VALVE SUBCODE Z	
9 10		11 12		13 14		15 16 17 18				19 20		21 22	
(17) LER/RO REPORT NUMBER 8 3		EVENT YEAR 8 3		SEQUENTIAL REPORT NO. 0 0 8		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0			
23 24		25 26		27 28		29 30		31 32					
ACTION TAKEN X		FUTURE ACTION X		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD 4 FORM SUB. Y	
33 34		35 36		37 38		39 40		41 42		43 44		45 46	
(18) (19)		(20)		(21)		(22)		(23)		(24)		(25)	
PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER R 2 9 0											
47 48		49 50		51 52		53 54		55 56		57 58		59 60	
(26)													

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event resulted from debris in the N003 vent line which prevented proper calibration

1 1 of the instrument due to an erroneous instrument float reservoir level indication.

1 2 The vent line was flushed, N003 and the float reservoir were cleaned and N003, Model

1 3 No. 83842-A8, was calibrated and the PT was satisfactorily completed. Plant Engineer-

ing will evaluate this event to determine applicable future action to this event.

FACILITY STATUS		% POWER		OTHER STATUS (30)		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION (32)	
E	(28)	0	7	8	(29)	NA	B	(31)	Periodic Test

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 Z 33 Z 34 NA
7 8 9 10 11 44

LOCATION OF RELEASE (36)
NA 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	40 NA

		LOSS OF OR DAMAGE TO FACILITY		(43)
		TYPE	DESCRIPTION	
1	9	Z	(42)	NA

7 8 9 10
PUBLICATION
ISSUED DESCRIPTION (45) 8302280507 830217
PDR ADOCK 05000324
NRC USE ONLY

2 0 N 44 DESCRIPTION S PDR

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521