



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640 JACKSON, MISSISSIPPI 39205

February 24, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Division 2 Diesel Shutdown Due  
to Tachometer Going  
Downscale while Speed was  
Being Increased  
LER 83-038/03 L-0  
AECM-83/0123

On January 25, 1983, while conducting a seismic qualification vibration test on the Division 2 Diesel Generator, the tachometer went downscale while speed was being increased. The diesel was then shutdown. This is being reported pursuant to Technical Specification 6.9.1.13.b as required by Technical Specification 4.8.1.1.3. Attached is LER 83-038/03 L-0.

Yours truly,

*J. P. McGaughy*  
for J. P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. K. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8303010178 830224  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
IE 22