



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 23, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Rated Doors Alarmed on
the Supervision System with
the Doors Closed
LER 83-033/99 X-0
AECM-83/0120

On January 18, 1983, fire rated doors 1A211, OC103, OC410, and OC706 alarmed on the supervision system with the doors closed. The doors were declared inoperable and fire watches were established in accordance with Technical Specification 3.7.7. Attached LER 83-033/99 X-0 is submitted as a Special Report in accordance with Technical Specification 3.7.7.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8303010193 830223
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
1822