

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
0	1	L	5	0	5	0	-	0	3	2	4	7	0	1	2	0	8	3	8	0	2	1	8	8	3	9															
7	8	60	61	68										69	74										75	80															

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

During steady state plant operation, the "RHR Reactor Pressure Low" annunciation was

received. An immediate check of plant operating parameters found no abnormalities.

This annunciation receives its input from reactor steam dome pressure low instruments,

2-B21-PJ-N021A-D, which provides input for the RHR and ECCS Core Spray Systems' LPCI

function. This event did not affect the health and safety of the public.

Technical Specifications 3.3.3, 3.5.3.1, 3.5.3.2, 6.9.1.9b

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	S	F	E	A	I	N	S	T	R	U	S	Z				
		9	10	11	12	13	18				19	20					
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
83		83		011		03		L		0							
21		22	23	24		25	26	27	28	29	30	31	32				
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
C	Z	Z		Z		0000		0000		N		Y		N		R369	
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

An electrical resistor and relay in instrument N021C had failed causing the instru-

ment to initiate the annunciation. The instrument, Model No. 510DU2, was replaced.

calibrated, and returned to service. As this event is isolated, no further corrective

action is planned.

1	4											80					
7	8	9											80				
FACILITY STATUS			% POWER			OTHER STATUS			(30)	METHOD OF DISCOVERY			DISCOVERY DESCRIPTION			(32)	80
1	5	E	(28)	0	8	0	(29)	NA	44	A	(31)	Operational Event					80
8	9	10	12	13											80		
ACTIVITY CONTENT			RELEASED OF RELEASE			AMOUNT OF ACTIVITY			(35)	LOCATION OF RELEASE			(36)	80			
1	6	Z	(33)	Z	(34)	NA	44	NA	45						80		
7	8	9	10	11											80		
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION			(39)	80				
1	7	0	0	0	(37)	Z	(38)	NA	13						80		
7	8	9	11	12	13											80	
PERSONNEL INJURIES			NUMBER			DESCRIPTION			(41)						80		
1	8	0	0	0	(40)	NA	12						80				
7	8	9	11	12											80		
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION			(43)						80		
1	9	Z	(42)	NA	10						80						
7	8	9	10											80			
PUBLICITY			ISSUED			DESCRIPTION			(45)						80		
2	0	N	(44)	NA	10						80						
7	8	9	10											80			
8303010197 830218															80		
PDR ADOCK 05000324															80		
S PDR															80		
										NRC USE ONLY					80		
7	8	9	10											80			

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521