

Mailing Address

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



Alabama Power

the southern electric system

63 FEB 10 A 8: 5

February 7, 1983

Docket No. 50-348
Docket No. 50-364

Mr. R. C. Lewis
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W.
Atlanta, GA 30303

SUBJECT: J. M. Farley Nuclear Plant NRC Inspection of November 27-
December 15, 1982

RE: Report No. 50-348/82-29
Report No. 50-364/82-30

Dear Mr. Lewis:

This letter refers to the violation in the subject inspection report which states:

"Technical Specification 6.8.1 requires written procedures be established and implemented.

Contrary to the above, on December 6, 1982, annunciator response procedures were not followed in that the causes of two alarmed annunciators on the emergency electrical control board, annunciators 201 and V51, were not promptly determined and corrected as required by their alarm response procedure, FNP-O-ARP-2, Revision 2."

Admission or Denial

The above violation occurred as described in the subject report.

Reason for Violation

The violation cited in the NRC inspection report was caused by personnel error. Operations personnel failed to utilize annunciator response procedures.

Corrective Actions Taken and Results Achieved

The cause for the annunciator was determined and the condition corrected. An operations memorandum has been written to licensed operations personnel discussing this incident and emphasizing the importance of responding to alarmed annunciators, knowing the cause for the annunciator and initiating prompt action to clear the annunciator. In addition, this incident will be discussed in the next requalification training cycle for licensed personnel.

Mr. R. P. Lewis
February 7, 1983
Page two

Corrective Steps Taken to Avoid Further Violations

See Above.

Date of Full Compliance


The operations memorandum was issued February 1, 1983. The discussion of this incident with licensed personnel will be completed by the end of the requalification training cycle on May 27, 1983.

Affirmation

I affirm that this response is true and correct to the best of my knowledge, information and belief.

The information contained in this letter is not considered to be of a proprietary nature.

Yours truly,


F. L. Clayton, Jr.

FLC/KWM:lw