



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 24, 1983

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Doors Alarmed on the
Supervision System and
Would Not Reset
LER 83-026/03 L-0
AECM-83/0122

On January 28, 1983, fire doors OC220 and 1A211 alarmed on the supervision system and would not reset. Fire detectors on one side of the doors were verified operable and an hourly fire watch was established in accordance with Technical Specification 3.7.7 action a. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-026/03 L-0.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8303010212 830224
PDR ADOCK 05000416
S PDR

member Middle South Utilities System

OFFICIAL COPY

IE 22