



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 24, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Fire Doors Blocked Open for  
Planned Maintenance  
Activities  
LER 83-029/03 L-0  
AECM-83/0121

On January 28, 1983, three fire doors were blocked open to allow the routing of electrical cords and air hoses for planned maintenance activities conducted in the Auxiliary Building. This required operating under the action statement of Technical Specification 3.7.7. The event is reported pursuant to Technical Specification 6.9.1.13.b. Attached is LER 83-029/03 L-0.

Yours truly,

*[Signature]*  
for J P McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8303010226 830224  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

IE 22