



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

February 24, 1983

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

83 FEB 25 A10:33

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Supervision System for Fire  
Door 1A215 Alarmed and  
Would not Reset  
LER 83-027/99 X-0  
AECM-83/0124

On January 28, 1983, fire door 1A215 alarmed on the supervision system and would not reset, yet the door was verified to be closed. Action a of Technical Specification 3.7.7 was entered. Attached LER 83-027/99 X-0 is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

*J. P. McGaughy*  
for J. P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

3303010343 830224  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22