NRC FORM 366 (12-81)

U.S. NUCLEAR REGULATORY COMMISSION
LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011 EXPIRES 4-30-82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | SCVCS1 (2) | 00-0000-00 (3) | 4 1 0 0 0 (4) | 1 (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 9 5 (7) | 0 1 2 7 8 3 (8) | 0 2 2 1 8 3 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On January 27, 1983, with the Plant in Mode 1, the Main Control Board indication
03 | (PI-486) for Steam Generator "B" Steam Pressure decreased approximately 100 psig.
04 | The "Steam Line Hi DP" alarm was also received at the time of the observed
05 | discrepancy in pressure indication. There were no adverse consequences as SCE&G
06 | complied with the Action Statement of the applicable Technical Specification.
07 |
08 |

09 | SYSTEM CODE IB (11) | CAUSE CODE E (12) | CAUSE SUBCODE X (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE T (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 008 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER (26) B080

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The event is attributed to a plugged transmitter sensing line. The inoperable
11 | channel was placed in the tripped condition within one (1) hour. Pressure
12 | transmitter PT-486 was found to have a plugged sensing line. The sensing line
13 | was back flushed and indication returned to normal. The licensee plans no
14 | additional action in regards to this event.

15 | FACILITY STATUS B (28) | % POWER 050 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) N/A

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

8303010457 830221
PDR ADOCK 05000395
S PDR

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A

NRC USE ONLY

NAME OF PREPARER C.J. McKinney PHONE: (803) 345-5209