

LICENSEE EVENT REPORT

CAR 1427

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N Y R E G 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
01 L 6 0 5 0 0 0 2 4 4 7 0 1 1 9 8 8 0 2 1 6 8 3 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 The Control Operator attempted to start the "B" Boric Acid Transfer Pump. After  
03 the pump started, it immediately tripped out and could not be restarted. The "B"  
04 Boric Acid Transfer Pump was declared inoperable. This is an LCO based on Tech.  
05 Spec. 3.2.3.b.  
06  
07  
08

09 P C 11 E 12 A 13 C K T B R K 14 B 15 Z 16  
7 8 9 10 11 12 13 18 19 20  
17 8 3 0 0 9 0 3 L 0  
21 22 23 24 26 27 28 29 30 31 32  
ACTION FUTURE EFFECT SHUTDOWN SEQUENTIAL OCCURRENCE REPORT REVISION  
TAKEN ACTION ON PLANT METHOD REPORT NO. CODE TYPE NO.  
A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 W I Z O 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The cause of the pump tripping out and failing to restart was failure of the  
11 control power fuses. The fuses were replaced and the pump restored to operable  
12 status.  
13  
14

15 E 28 1 0 0 29 NA A 31 Operator Awareness 32  
7 8 9 10 12 13 44 45 46 80  
ACTIVITY CONTENT AMOUNT OF ACTIVITY LOCATION OF RELEASE  
16 Z 33 Z 34 NA NA 36  
7 8 9 10 11 44 45 80  
PERSONNEL EXPOSURES  
NUMBER TYPE DESCRIPTION 39  
17 0 0 0 37 Z 38 NA  
7 8 9 11 12 13 80  
PERSONNEL INJURIES  
NUMBER DESCRIPTION 41  
18 0 0 0 40 NA  
7 8 9 11 12 80  
LOSS OF OR DAMAGE TO FACILITY  
TYPE DESCRIPTION 43  
19 Z 42 NA  
7 8 9 10 80  
PUBLICATION  
ISSUED DESCRIPTION 45  
20 N 44 NA  
7 8 9 10 80

8303010487 830216  
PDR ADDCK 05000244  
S PDR

NRC USE ONLY

NAME OF PREPARER J. C. Bodine

PHONE: (315) 524-4446