



**LOUISIANA**  
**POWER & LIGHT**

142 DELARONDE STREET  
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 365-2345

**L. V. MAURIN**  
*Vice President Nuclear Operations*

February 11, 1983

W3P83-0502  
Q-3-A20.18  
3-A1.01.04  
L.09.02

Director of Nuclear Reactor Regulation  
ATTENTION: G. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUBJECT: Waterford 3 SES  
Docket No. 50-382  
Seismic Qualification of Equipment

Reference: NRC letter, G. W. Knighton to L. V. Maurin  
dated January 28, 1983


Dear Mr. Knighton:

The purpose of this letter is to address the last remaining seismic qualification item mentioned in the above referenced letter. The response to this item (generic issue 2) is as follows.

Ebasco has evaluated the seismic qualification method for equipment which is mounted on the containment structure (vessel) and for which, as seismic input criteria, containment structure floor response spectrum curves are specified. The conclusion of this evaluation is that none of the above equipment (i.e. mounted on the vessel) is qualified by a single frequency method.

If you have any questions, please advise.

Yours very truly,

  
L. V. Maurin

LVM/SMJ/ssd

cc: Jim Wilson (NRC), Jerry Jackson (NRC), Jag Singh (EG&G), L. Blake, W. M. Stevenson

3001

8303010499 830211  
PDR ADOCK 05000382  
A PDR