

DUKE POWER COMPANY

U.S. NUCLEAR REGULATORY COMMISSION
P.O. BOX 33189
ATLANTA, GEORGIA 30303

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

83 FEB 25 10:33

February 18, 1983


Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: McGuire Nuclear Station Unit 1
Docket No. 50-369

Dear Mr. O'Reilly:

Please find attached Reportable Occurrence Report RO-369/83-04. This report concerns T.S.3.8.2.3, "The following D.C. channels shall be operable and energized: a. Channel 1 consisting of 125-volt D.C. bus no. EVDA, 125-volt D.C. battery bank no. EVCA and a full capacity charger...". This incident was considered to be of no significance with respect to the health and safety of the public.

Very truly yours,



Hal B. Tucker

PBN:jfw
Attachment

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Senior Resident Inspector
McGuire Nuclear Station

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8303010562 830218
PDR ADDCK 05000369
S PDR

OFFICIAL COPY

IE 22